



# MAINTENANCE SCHEDULE




Technician	Date	Actual Hours	Machine Hours	Coolant Filter	PDM Filter	Air Filter	Separator Element	Coolant	Oil Analysis	SPM Readings	Check List	Grease Motors (if applicable)	Miscellaneous
WRITE IN PART NUMBER →													
			2000	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
			4000	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
			6000	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
			8000	✓	✓	✓	✓	✓	✓	✓	✓	✓	4423
			10000	✓	✓	✓	✓	✓	✓	✓	✓	✓	6270
			12000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			14000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			16000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			18000	✓	✓	✓	✓	✓	✓	✓	✓	✓	161
			20000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			22000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			24000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			26000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			28000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			30000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			32000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			34000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			36000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			38000	✓	✓	✓	✓	✓	✓	✓	✓	✓	
			40000	✓	✓	✓	✓	✓	✓	✓	✓	✓	



VISUAL INSPECTION OF THE FOLLOWING ITEMS IS RECOMMENDED FOR EVERY 2000-HR OPERATION INTERVAL:  
 SCAVENGE SCREEN, HOSES, HIGH TEMPERATURE SWITCH, SAFETY VALVES, COOLERS, MOISTURE SEPARATOR DRAIN AND MOTOR COWL.



FOR SERVICE CONTACT:



More Than Air. Solutions.  
 On Line Solutions: [www.air.irco.com](http://www.air.irco.com)